

MAINTAIN YOUR MODULAR WINTER CHECKLIST



- Thermostat between 68–74 degrees

70

Replace HVAC filters quarterly
- Keep all HVAC system supply registers open

Wrap water lines in heat tape — in regions that freeze
- Clean all gutters to prevent leaks

Clean condenser coils quarterly
- Lubricate door locks and hardware

Report any signs of water intrusion immediately